

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


NO...2454

Date...30/10/2023

It is certified that an inspection team headed by Md. Mahboob Alam, JUNIOR ENGINEER (Name of Officers with designation) from PUBLIC HEALTH DIVISION, KISHANGANJ (Name of Department/office) inspected the Saraswati Vidya Mandir School (Name & Address of the School) AT-Motibagh, PO-Kishanganj, PS-Kishanganj, DIST-KISHANGANJ BIHAR-855107 and found that the Saraswati Vidya Mandir School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of ONE YEAR


Signature with seal:



Name: Md. Mahboob Alam.

Designation Junior Engineer.

Signature with seal:


Name: **Executive Engineer**
P.H. DIVISION
KISHANGANJ

Designation

DISTRICT LEVEL WATER TESTING LABORATORY

UNDER

P.H. DIVISION KISHANGANJ

Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj.

District - Kishanganj

Sample Collected By:- School Staff.			Date of Sample Submission :- 28.10.2023					Date Of Testing:-30.10.2023						
Sl. No	Block	Panchyat	Location	Turb.	PH	Fe	TH	Cl	Ca	Mg	Fluoride	Cond.	T.D.S	Remark
1	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Kishanganj (Tube well)	2	7.2	0.68	68	16	21	5	0.92	104	68	
2	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Kishanganj (Treated Water)	B.D.L	7.0	0.44	60	13	16	5	0.28	86	56	
Desirable limit				1 mg/l	6.5-8.5	1.0 mg/l	200 mg/l	250 mg/l	75 mg/l	30 mg/l	1.0mg/l	500 mg/l	
permissible limit in absence of alternate source IS:10500 :2012				5 mg/l	NR	NR	600 mg/l	1000 mg/l	200 mg/l	100 mg/l	1.5mg/l		2000 mg/l	

NR- No Relaxation

30/10/2023
Kishanganj
Chemist/Lab.Assistant
P.H. Division Kishanganj

25/10/23
Assistant Engineer
P.H.Sub. Division.Kishanganj

Executive Engineer
P.H.Division Kishanganj