

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO.....1101

Dated.....12.06.25

It is certified that an inspection team headed by Iftakhar Ansari.....Junior Engineer (Name of Officers with designation) From Nagar Parishad, Kishanganj. PHED inspected the Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj, Bihar Pin-855107 (Name & Address of the School) on 04.6.25..... (date of inspection) and on the basis of Water Test Report Attached bearing no.....1101 dated.....12.06.25 of District Level Water Testing Laboratory under P.H.Division Kishanganj Certified that the Saraswati Vidya Mandir (Name of School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid till One Year.

Iftakhar Ansari  
04/06/25  
JE

Signature with seal:

Name:- Sunil Kumar Deepak

Designation :- Executive Engineer

Name &amp; Address of the Office/Department :- Public Health Division, Kishanganj

To,

Saraswati Vidya Mandir,  
Motibagh, Teusa,  
Kishanganj, Bihar  
Pin-855107  
(Name & Address of the Institution)

Note :- The certificate is to be issued by authorized officer/PHED Lab/local bodies.

**DISTRICT LEVEL WATER TESTING LABORATORY**  
**UNDER**

**P.H. DIVISION KISHANGANJ**

**Physico-Chemical Examination Report of Drinking Water Sample of Kishanganj**

Sample Collected By : - School Staff							Date of Sample Submitted in Lab :- 29.05.2025							
District-Kishanganj							Date of Reporting :- 04.06.2025							
Sl.No	Block	Panchyat	Location	Turb.	PH	Fe	TH	Alkalinity	Ca	Mg	Cl	Cond.	T.D.S	Remarks
1	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj (Hand Pump)	2.17	7.24	0.63	40.8	43.56	8.16	4.95	15.76	104	68	
2	Kishanganj	Nagar	Saraswati Vidya Mandir, Motibagh, Teusa, Kishanganj (Treated Water)	1.09	6.96	0.47	69.36	63.36	16.32	6.94	45.33	227	147	
Desirable limit				1 NTU	6.5-8.5	1.0 mg/l	200 mg/l	200mg/l	75mg/l	30mg/l	250mg/l	....	500 mg/l	
permissible Limit in absence of alternate source IS:10500 :2012				5 NTU	NR	NR	600 mg/l	600mg/l	200mg/l	100mg/l	1000mg/l	μ mhos/cm	2000 mg/l	

NR- No Relaxation

*[Signature]*  
04/06/25  
Lab.Assistant  
P.H. Division Kishanganj

*[Signature]*  
04/06/25  
Chemist  
P.H.Division Kishanganj

*[Signature]*  
04/06/25  
Assistant Engineer  
P.H.Sub. Division Kishanganj